

# 👁 Daily Visual Inspection Checklist for Diesel Generators (GPH Edition)

## For Standby, Industrial & Rental Units

---

### ✓ 1. Exterior & Safety Condition

- 🟡 Generator exterior clean and free from dust/debris
- 🔒 Panels and doors secured properly
- 🚫 No signs of vandalism or tampering
- ⚠ Emergency stop button accessible and functional

---

### ⚡ 2. Electrical System Check

- 📊 Control panel display ON and error-free
- ⚠ No warning/error codes present
- 🔋 Battery terminals clean, tight, and corrosion-free
- 🔌 Cables, connectors & harnesses free from damage

---

### 탱 3. Fuel System

- 🔥
- 🧪 No fuel leaks detected
- 탱 Fuel tank cap secure
- 🧣 Fuel lines tight with no cracks or wetness

---

### 🌡 4. Cooling System

- 💧 Coolant level within safe range
- 🌀 Radiator clean and unobstructed
- 🔧 Hoses tight with no leaks
- 💨 Fan belt intact with proper tension

## 5. Lubrication System

-  Engine oil level OK
-  No oil leakage under engine or around seals
-  Oil filter area clean

---

## 6. Exhaust & Air System

-  Exhaust path clear and unobstructed
-  No visible black/white/blue smoke (during brief test run)
-  Air filter housing clean and secured

---

## 7. General Operational Readiness

-  Battery charger ON and working
-  Auto/Manual switch in correct mode
-  All alarms and indication lights functional
-  ATS communication/control cables intact
-  Logbook updated

---

## Inspector Details

-  Operator/Technician Name
-  Date
-  Time
-  Site/Location
-  Signature